

SCHEDULE – ‘B’

LOCATION WISE LIST OF FIRE FIGHTING SYSTEM EQUIPMENTS AND FIRE EXTINGUISHERS

Sr. No.	Description	Qty.
(A)	Sampada Bldg. (MDC Bldg.) - Height 19.8 Mtr.	
1	Fire Alarm Panel	01 Nos.
2	Smoke / Heat Detector	129 Nos.
3	MCP Point	06 Nos.
4	Hooter	07 Nos.
	Fire Hydrant System	
5	Hydrant System	12 Nos.
6	Hose Box	12 Nos.
7	Hose Reel	12 Nos.
8	Electric Pumps with Starter (5 HP, 3PH)	01 Nos.
(B)	Sanwad Bldg. (MDC Auditorium) - Height 18.25 Mtr.	
1	Fire Alarm Panel	01 Nos.
2	Smoke / Heat Detector	41 Nos.
3	MCP Point	08 Nos.
4	Hooter	06 Nos.
	Fire Hydrant System	
5	Hydrant System	11 Nos.
6	Hose Box	10 Nos.
7	Hose Reel	11 Nos.
8	Electric Pumps with Starter (5 HP, 3PH)	01 Nos.
9	Sprinklers	22 Nos.
(C)	Administrative Bldg. - Height 13 Mtr.	
1	Fire Alarm Panel	01 Nos.
2	Smoke / Heat Detector	47 Nos.
3	MCP Point	04 Nos.
4	Hooter	05 Nos.
	Fire Hydrant System	
5	Hydrant System	05 Nos.
6	Hose Box	05 Nos.
7	Hose Reel	04 Nos.
8	Electric Pumps with Starter (5 HP, 3PH)	01 Nos.
(D)	PMB - Height 17.87 Mtr.	
1	Fire Alarm Panel	01 Nos.
2	Smoke / Heat Detector	155 Nos.
3	MCP Point	10 Nos.
4	Hooter	10 Nos.
	Fire Hydrant System	
5	Hydrant System	06 Nos.
<u>6</u>	<u>Hose Box</u>	<u>06 Nos.</u>

7	Hose Reel	05 Nos.
8	Electric Pumps with Starter (5 HP, 3PH)	01 Nos.
(E)	CIT / RECORD ROOM/RTI/CDM/LIBRARY	
1	Fire Alarm Panel	01 Nos.
2	Smoke / Heat Detector	83 Nos.
3	MCP Point	05 Nos.
4	Hooter	05 Nos.
(F)	DAC Auditorium	
1	Fire Alarm Panel	01 Nos.
2	Smoke / Heat Detector	10 Nos.
3	MCP Point	02 Nos.
4	Hooter	02 Nos.

RENEWAL OF NOC

Sr. No.	Buildings	NOC Renewal
1.	MDC Building (Sampada) & Administrative Bldg.	As per NOC's Due Dates
2.	MDC Auditorium Bldg. (Sanwad)	
3.	Project Management Building(PMB)	

DETAILS INSTALLATION CHART FOR REFILING AND SERVICING OF FIRE EXTINGUISHERS AT YASHADA CAMPUS

Sr. No.	Location	Fire Extinguisher type	Cap.	Total Qty.
1.	Admin Building	ABC type	6kg.	05 nos.
2.	Sampada Building	ABC type	6kg.	06 nos.
3.	Sampada Kitchen & Panel Room	ABC type	6kg.	03 nos.
4.	Sanwad Auditorium	ABC type	6kg.	10 nos.
5.	Sanwad / Sanwad (Panel Room)	Co2 type	4.5kg.	02 nos
6.	Jubilee	ABC type	6kg.	04 nos.
7.	Kojagiri Mess	ABC type	6kg.	03 nos.
8.	Kasturi & Koustubh Bungalow	ABC type	6kg.	02 nos.
9.	Lezim	ABC type	6kg.	03 nos.
10.	Shamee	ABC type	6kg.	04 nos.
11.	Academy Block	ABC type	6kg.	05 nos.
12.	Durva-I	ABC type	6kg.	04 nos.
13.	Durva –II	ABC type	6kg.	04 nos.
14.	Library	ABC type	6kg.	02 nos.
15.	Library	ABC type	6kg.	02 nos.
16.	CDM	ABC type	6kg.	02 nos.
17.	CIT	ABC type	6kg.	02 nos.
18.	CIT	Co2 type	4.5kg.	01 no
19.	Main Gate	Co2 type	4.5kg.	01 no.

Sr. No.	Location	Fire Extinguisher type	Cap.	Total Qty.
20.	Main Gate	ABC type	6kg.	01 nos.
21.	E- Governance (Record Room)	ABC type	6kg.	03 nos.
22.	New Panel Room	ABC type	6kg.	02 nos.
23.	Jhansi Canteen	ABC type	6kg.	01 no.
24.	Kohinoor Bungalow (Security Cabin)	ABC type	6kg.	01 no.
25.	Kohinoor Bungalow (Security Cabin)	ABC type	2kg.	01 no.
26.	Dormitory Building	ABC type	6kg.	01 no.
27.	PMB	ABC type	6kg.	10 Nos.
28.	PMB Ground floor	Co2 type	4.5kg	02 Nos.
29.	DAC Auditorium	ABC type	6kg.	02 Nos.
Final Summary of Fire Extinguishers				
1.	ABC type fire extinguishers of 6 kg capacity		81 nos.	
	ABC type fire extinguishers of 2 kg capacity		2 no.	
2.	Co2 type fire extinguishers of 4.5 kg capacity		06 nos.	
	Total Qty.		89 nos.	

I agree to execute the above work as per Schedule – ‘B’ at cost Rs. _____/- + (_____ % GST)

(In words :- _____)

(For Two Years Period)

The above rates should be inclusive of all admissible taxes, levies, duties & transport excluding GST. The GST rates should be shown separately. The rates change in GST shall be applicable and paid by yashada from time to time.

Signature & Stamp of the Contractor